

FORM 9
CERTIFICATE OF SUBSTANTIAL PERFORMANCE OF THE
CONTRACT UNDER SECTION 32 OF THE ACT

Construction Act

(County/District/Regional Municipality/Town/City in which premises are situated)

(street address and city, town, etc., or, if there is no street address, the location of the premises)

This is to certify that the contract for the following improvement:

(short description of the improvement)

to the above premises was substantially performed on _____ .
(date substantially performed)

Date certificate signed: _____

(payment certifier where there is one - signature required)

(owner and contractor, where there is no payment certifier -
signatures required)

Name of owner: _____

Address for service: _____

Name of contractor: _____

Address for service: _____

Name of payment certifier (where applicable): _____

Address: _____

(Use A or B, whichever is appropriate)

☐ A. Identification of premises for preservation of liens:

(if a lien attaches to the premises, a legal description of the premises,
including all property identifier numbers and addresses for the premises)

☐ B. Office to which claim for lien must be given to preserve lien:

(if the lien does not attach to the premises, the name and address of the person or body to whom the claim for lien must be given)



MAT 4SITE ENGINEERS LTD.

620 WILSON AVENUE, SUITE 320, TORONTO, ON M3K 1Z3
Phone: 416-229-6574 Fax: 416-229-4105

October 30, 2020

ATTN:

Angelo Ricci, RSE

Mechanical & Electrical Supervisor, Facility Management
Facility Management
905 832 2281 ext.6166 | C: 416 891 9141
angelo.ricci@vaughan.ca

Re : **Substantial Completion Letter**
Project Title : **Al Palladini Sprinkler Installation**
Location : **9201 Islington Ave, Woodbridge, ON L4L 1A7**
M4S Project No. : **19419**
Permit No. : **19-001328**

During the course of construction of the above project, personnel from MAT 4Site Engineers Ltd and Elite Sprinkler Ink. firm carried out periodic site reviews of mechanical work in accordance with the requirements of Division C, subdivision 1.2.2 of the Ontario Building Code and the requirements of section 2 of Ontario Regulation 260/08, made under the Professional Engineers Act, 1990, as amended. These reviews were conducted following the procedures described in the Professional Engineers Ontario Guideline for Professional Engineers Providing General Review of Construction as Required by the Ontario Building Code.

On the basis of these reviews and the basis of site visit reports submitted to our firm, it is our opinion that the work is in general conformity with the drawings and specifications prepared by Elite Sprinkler Inc. under the professional seal of Andrei Novosselov, P.Eng., which formed the basis for issuance of the building permit and any changes thereto authorized by the Chief Building Official.

Please do not hesitate to contact the undersigned if you have any questions.

Best regards,

A handwritten signature in blue ink, reading 'Anthony Colin', with a stylized flourish.

Anthony Colin, P.Eng. M.Eng.
Engineering Manager
MAT 4Site Engineers Ltd.



Automatic Fire Protection Sprinkler System Design

PEO Certificate of Authorization #100172288
22 McDonnell Cres., Bradford, Ontario, L3Z 0S7
T: 905-505-1370
www.elitesprinkler.ca

INSPECTION LETTER

Date: July 02, 2020

Re: Dry Sprinkler System Replacement
9201 Islington Avenue
Woodbridge, ON.
Building Permit: 19-1328

To whom it may concern:

The dry sprinkler system installation at the above mentioned location is in compliance with **ELITE SPRINKLER INC.** drawings no. **2019-237-SP1**, and applicable codes and standards (O.B.C. 2012ed., N.F.P.A.# 13 2013ed.), subject to the following comments:

1. Completed Contractor's Material and Test Certificates are to be forwarded to the local fire authority.

Note: Installation of sprinkler system at the above mentioned location was done by Lifeline Fire Protection.

Sincerely,
Andrei Novosselov, P Eng.

